



Service company, LLC

2A Dal'nevostochnaya Street, office 201, Samara, 443051
Tel./fax: (846) 373-81-37, e-mail: info@servcompany.ru

ATTN: O.N. Ekaterinina
Director General
of SKB EP, LLC

Review of SKB EP, LLC instrument operation

Dear Olga Nikolaevna!

I send you review on the operation of the instrument milli-ohmmeter «MIKO-7MA», this feedback is compiled on the basis of the annual operation of this instrument in various weather conditions and at various measurement objects.

Milli-ohmmeter «MIKO-7MA» is usually used to measure the transformers parameters, namely to measure DC resistance of windings, as well as for measuring the contact resistance of commutation devices during start-up and commissioning and operation.

During the operation, there were no significant remarks to the instrument except for a very long charging, but this comment is not essential as it was most likely due to the low temperature of the battery after transportation. I believe this instrument is better than the competitor SONEL MMR600, as measurements are faster, battery charge lasts for a long time, and the instrument works more «Stable».

From the improvements I would like to have longer cables, as well as the connectors that are installed on them from the connection of the «Crocodile» clamps would have a more rigid fixation to these clamps.

In conclusion, I would like to note that the milli-ohmmeter «MIKO-7MA» is convenient to use and reliable at the moment. The instrument was purchased on the recommendation of a related organization that has been using it for a long time, which is why I can recommend it for the above works.

Head of the electrical measurement
laboratory of LLC «SC»



Lukyanchik V.N.

Lukyanchik V.N.
89379858748