



# Limited liability company **Uralklektrostroy**

« 17 » 08 2020 г. № 03/17-20

ATTN: O.N. Ekaterinina  
Director General  
of SKB EP, LLC

Dear Olga Nikolaevna!

Our company purchased PKV/U3.0 circuit breaker analyzer in 2008. For the years passed, I would like to note proper and stable operation of the device during circuit breakers diagnostics. PKV/U3.0 perfectly copes with the following tasks:

- \* measuring speed and time parameters of the circuit breaker operation;
- \* measuring the duration of the contactless pause in the "O-C-O" cycle;
- \* performing simultaneous characteristics measurement by three phases;
- \* automatic graphs registration that illustrate information about the state

of the circuit breaker.

An important benefit is that we are able to independently add specific templates to the program of the device. One more benefit for us is that the device is focused on diagnostics of air circuit breakers. The only drawbacks that we figured out during the years of device's use are the lack of the usb port for connecting to a laptop, the unprotected case, and the weight of the device itself.

We definitely recommend PKV/U3.0 device to all companies that operate circuit breakers, as well as to mobile laboratories that make circuit breakers diagnostics.

We allow you to use this review for advertising purposes.

Deputy Chief Engineer



A.P. Logutov